

Building Act 1993

Building Interim Regulations 2017

REGULATION 1507: CERTIFICATE OF COMPLIANCE—DESIGN

To:

Relevant Building Surveyor: Peter Dimitrakopoulos, PLP Building Surveyors & Consultants Pty Ltd
Postal Address: Level 4, 63 Exhibition Street Melbourne, Vic Post Code: 3000

From:

Building Practitioner: *Z. Sajnovic*
Category/Class: *Engineer/Civil* Registration No: *EC 23514*
Postal Address: *PO Box 336 NORTH MELBOURNE, Vic* Post Code: *3051*

Property details:

Number: 412	Street/road: St. Kilda Road	City/suburb/town: Melbourne
Lot/s:	LP/PS:	Volume: Folio:
Crown Allotment:	Section:	Parish: County:
Municipal District:		

Compliance:

I did / ~~did not~~ prepare the design, and certify that the part(s) of the design described as
16x8 gantry platform designed to support an ALIMAK on one side, two beams intended to carry scaffolding legs and standard fall protection live load over the remainder of the floor
comply with the following provisions of the Regulations: *AS1170 part 1 & 2, AS1250, AS1720.1, AS2870.1, AS4100*

Design documents

Complying:

Drawings No: 032/2018 Sheets: S1-S3 Prepared by: McIver Contractors Date: 27.04.18
and checked by ZS Consulting, job no. 18-42.23 sheets SK1-3 and dated 15.05.18

Used to assess the documents above, but not approved:

Computations: 18-42.23 Pages : 6 Prepared by: ZS Consulting Date: Mar. 2018

Alimak design loads: job number 18069, dated 15/05/18 by Alimak Hek

Individual leg load from scaffolding not exceeding more than 31kN (unfactored)

Signature

.....
Signed: *Zlatko Sajnovic* Date: 15.05.18